

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

JAN 14 2009

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of December 2008

PLANT OUTPUT

Well No.	Permit No.	KWH Produced	KWH to Sales	Gallons Produced	Average Temp.
27-33	626			0.00 MMgal	Not Flowed
28-33	243			104.91 MMgal	339 Deg F.
37-33	426			98.80 MMgal	332 Deg F.
45-33	627			0.00 MMgal	Not Flowed
63-7	214			54.37 MMgal	315 Deg F.
73-7	77			48.74 MMgal	319 Deg F.
73B-7	428			64.35 MMgal	322 Deg F.
74-7	65			49.20 MMgal	322 Deg F.
76A-7	343			61.29 MMgal	322 Deg F.
82-7	88			0.00 MMgal	Not Flowed
84-7	623			0.00 MMgal	Not Flowed
Totals		41,536.4 MWH	37,950.2 MWH	481.66 MMgal	

This report to be filed by the end of the month following the month herein reported

Water produced for injection augmentation:


73W-7
 Goerenger

Temp.
 81 Deg F.
 Not Flowed

Production
 495.32 MMgal
 0.00 MMgal

Pressure
 83 psig.
 Not Flowed

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 

Doug Brown

Position Site Manager

Telephone (775) 423-6535

Date January 12, 2009

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

RECEIVED

JAN 14 2009

Division of Minerals

January 12, 2009

Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the *December* Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 850-2266 should you have any questions.

Sincerely,

Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521
 Project Dixie Valley Unit County Churchill Month of November 2008

PLANT OUTPUT

Well No.	Permit No.	KWH Produced	KWH to Sales	Gallons Produced	Average Temp.
27-33	626			0.00 MMgal	Not Flowed
28-33	243			101.20 MMgal	341 Deg F.
37-33	426			95.30 MMgal	334 Deg F.
45-33	627			0.00 MMgal	Not Flowed
63-7	214			55.02 MMgal	318 Deg F.
73-7	77			45.72 MMgal	319 Deg F.
73B-7	428			60.36 MMgal	323 Deg F.
74-7	65			56.81 MMgal	324 Deg F.
76A-7	343			57.45 MMgal	322 Deg F.
82-7	88			0.00 MMgal	Not Flowed
84-7	623			0.00 MMgal	Not Flowed
Totals		41,237.8 MWH	37,557.9 MWH	471.85 MMgal	

This report to be filed by the end of the month following the month herein reported

Water produced for injection augmentation:	Temp.	Production	Pressure
73W-7	82 Deg F.	493.65 MMgal	81 psig.
Goerenger	Not Flowed	0.00 MMgal	Not Flowed

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown

Position Site Manager

Telephone (775) 423-6535

Date December 9, 2008

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

December 9, 2008

RECEIVED

DEC 10 2008

Division of Minerals


Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the November Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

NOV 13 2008

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of October 2008


PLANT OUTPUT

Well No.	Permit No.	KWH Produced	KWH to Sales	Gallons Produced	Average Temp.
27-33	626			0.00 MMgal	Not Flowed
28-33	243			104.79 MMgal	341 Deg F.
37-33	426			98.68 MMgal	335 Deg F.
45-33	627			0.00 MMgal	Not Flowed
63-7	214			58.16 MMgal	319 Deg F.
73-7	77			46.01 MMgal	319 Deg F.
73B-7	428			60.74 MMgal	324 Deg F.
74-7	65			60.05 MMgal	324 Deg F.
76A-7	343			57.62 MMgal	321 Deg F.
82-7	88			0.00 MMgal	Not Flowed
84-7	623			0.00 MMgal	Not Flowed
Totals		42,741.4 MWH	38,865.3 MWH	486.04 MMgal	

This report to be filed by the end of the month following the month herein reported

Water produced for injection augmentation:	Temp.	Production	Pressure
73W-7	80 Deg F.	543.41 MMgal	71 psig.
Goerenger	Not Flowed	0.00 MMgal	Not Flowed

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown
 Position Site Manager

Telephone (775) 423-6535

Date 11/11/08

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

RECEIVED

NOV 13 2008

Division of Minerals

November 11, 2008


Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the October Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

OCT 07 2008

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of September 2008

PLANT OUTPUT

Well No.	Permit No.	KWH Produced	KWH to Sales	Gallons Produced	Average Temp.
27-33	626			0.00 MMgal	Not Flowed
28-33	243			100.37 MMgal	340 Deg F.
37-33	426			94.56 MMgal	337 Deg F.
45-33	627			0.00 MMgal	Not Flowed
63-7	214			57.96 MMgal	320 Deg F.
73-7	77			44.80 MMgal	319 Deg F.
73B-7	428			59.17 MMgal	324 Deg F.
74-7	65			59.72 MMgal	324 Deg F.
76A-7	343			55.57 MMgal	321 Deg F.
82-7	88			0.00 MMgal	Not Flowed
84-7	623			0.00 MMgal	Not Flowed
Totals		40,530.5 MWH	36,598.9 MWH	472.16 MMgal	

This report to be filed by the end of the month following the month herein reported

Water produced for injection augmentation:	Temp.	Production	Pressure
73W-7	81 Deg F.	68.22 MMgal	64 psig.
Goerenger	Not Flowed	0.00 MMgal	Not Flowed

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown
 Position Site Manager

Telephone (775) 423-6535

Date 10/6/08

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

RECEIVED

OCT 07 2008

Division of Minerals

October 6, 2008


Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the *September* Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

SEP 09 2008

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of August 2008


PLANT OUTPUT

Well No.	Permit No.	KWH Produced	KWH to Sales	Gallons Produced	Average Temp.
27-33	626			0.00 MMgal	Not Flowed
28-33	243			102.80 MMgal	340 Deg F.
37-33	426			96.82 MMgal	340 Deg F.
45-33	627			0.00 MMgal	Not Flowed
63-7	214			58.91 MMgal	321 Deg F.
73-7	77			46.39 MMgal	320 Deg F.
73B-7	428			61.24 MMgal	325 Deg F.
74-7	65			59.45 MMgal	325 Deg F.
76A-7	343			57.00 MMgal	321 Deg F.
82-7	88			0.00 MMgal	Not Flowed
84-7	623			0.00 MMgal	Not Flowed
Totals		43,154.3 MWH	38,915.4 MWH	482.60 MMgal	

This report to be filed by the end of the month following the month herein reported

Water produced for injection augmentation:	Temp.	Production	Pressure
73W-7	82 Deg F.	600.55 MMgal	63 psig.
Goerenger	Not Flowed	0.00 MMgal	Not Flowed

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown
 Position Site Manager

Telephone (775) 423-6535

Date 9/8/08

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

RECEIVED

SEP 09 2008

Division of Minerals

September 8, 2008


Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the August Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

AUG 13 2008

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of July 2008


PLANT OUTPUT

Well No.	Permit No.	KWH Produced	KWH to Sales	Gallons Produced	Average Temp.
27-33	626			0.00 MMgal	Not Flowed
28-33	243			102.86 MMgal	340 Deg F.
37-33	426			97.14 MMgal	341 Deg F.
45-33	627			0.00 MMgal	Not Flowed
63-7	214			60.51 MMgal	321 Deg F.
73-7	77			47.24 MMgal	321 Deg F.
73B-7	428			62.06 MMgal	325 Deg F.
74-7	65			61.78 MMgal	325 Deg F.
76A-7	343			57.75 MMgal	321 Deg F.
82-7	88			0.00 MMgal	Not Flowed
84-7	623			0.00 MMgal	Not Flowed
Totals		43,373.9 MWH	39,048.8 MWH	489.33 MMgal	

This report to be filed by the end of the month following the month herein reported

Water produced for injection augmentation:	Temp.	Production	Pressure
73W-7	82 Deg F.	585.98 MMgal	66 psig.
Goerenger	Not Flowed	0.00 MMgal	Not Flowed

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown
 Position Site Manager

Telephone (775) 423-6535

Date 8/12/08

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

RECEIVED

AUG 13 2008

Division of Minerals

August 12, 2008

Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the July Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NEMG

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of June 2008

PLANT OUTPUT

Well No.	Permit No.	KWH Produced	KWH to Sales	Gallons Produced	Average Temp.
27-33	626			0.00 MMgal	Not Flowed
28-33	243			101.70 MMgal	340 Deg F.
37-33	426			95.78 MMgal	341 Deg F.
45-33	627			0.00 MMgal	Not Flowed
63-7	214			59.00 MMgal	322 Deg F.
73-7	77			46.48 MMgal	322 Deg F.
73B-7	428			61.36 MMgal	326 Deg F.
74-7	65			60.92 MMgal	326 Deg F.
76A-7	343			55.78 MMgal	322 Deg F.
82-7	88			0.00 MMgal	Not Flowed
84-7	623			0.00 MMgal	Not Flowed
Totals		42,764.7 MWH	38,635.7 MWH	481.02 MMgal	

This report to be filed by the end of the month following the month herein reported

Water produced for injection augmentation:	Temp.	Production	Pressure
73W-7	82 Deg F.	545.56 MMgal	69 psig.
Goerenger	Not Flowed	0.00 MMgal	Not Flowed

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown

Position Site Manager

Telephone (775) 423-6535

Date 7/2/08

RECEIVED

JUL 03 2008

Division of Minerals

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

July 2, 2008


Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the *June* Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

JUN 10 2008

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Division of Minerals

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of May 2008

PLANT OUTPUT

Well No.	Permit No.	KWH Produced	KWH to Sales	Gallons Produced	Average Temp.
27-33	626			0.00 MMgal	Not Flowed
28-33	243			105.82 MMgal	341 Deg F.
37-33	426			99.66 MMgal	339 Deg F.
45-33	627			0.00 MMgal	Not Flowed
63-7	214			62.18 MMgal	322 Deg F.
73-7	77			48.79 MMgal	322 Deg F.
73B-7	428			64.42 MMgal	327 Deg F.
74-7	65			63.61 MMgal	326 Deg F.
76A-7	343			56.70 MMgal	322 Deg F.
82-7	88			0.00 MMgal	Not Flowed
84-7	623			0.00 MMgal	Not Flowed
Totals		44,515.5 MWH	40,263.5 MWH	501.18 MMgal	

This report to be filed by the end of the month following the month herein reported

Water produced for injection augmentation:	Temp.	Production	Pressure
73W-7	83 Deg F.	570.86 MMgal	72 psig.
Goerenger	Not Flowed	0.00 MMgal	Not Flowed

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown

Position Site Manager

Telephone (775) 423-6535

Date 6/9/08

Ch

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

RECEIVED

JUN 10 2008

Division of Minerals

June 9, 2008

Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the May Reports of Production and Injection for the Caithness Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

MAY 09 2008

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of April 2008


PLANT OUTPUT

Well No.	Permit No.	KWH Produced	KWH to Sales	Gallons Produced	Average Temp.
27-33	626			0.00 MMgal	Not Flowed
28-33	243			101.92 MMgal	348 Deg F.
37-33	426			95.98 MMgal	334 Deg F.
45-33	627			0.00 MMgal	Not Flowed
63-7	214			60.29 MMgal	322 Deg F.
73-7	77			48.07 MMgal	323 Deg F.
73B-7	428			63.46 MMgal	328 Deg F.
74-7	65			62.25 MMgal	327 Deg F.
76A-7	343			53.85 MMgal	322 Deg F.
82-7	88			0.00 MMgal	Not Flowed
84-7	623			0.00 MMgal	Not Flowed
Totals		43,429.5 MWH	39,524.0 MWH	485.82 MMgal	

This report to be filed by the end of the month following the month herein reported

Water produced for injection augmentation:	Temp.	Production	Pressure
73W-7	84 Deg F.	497.44 MMgal	75 psig.
Goerenger	Not Flowed	0.00 MMgal	Not Flowed

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown
 Position Site Manager

Telephone (775) 423-6535

Date 5/8/08

du

RECEIVED

MAY 09 2008

Division of Minerals

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

May 8, 2008


Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the April Reports of Production and Injection for the Caithness Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

RECEIVED

APR 23 2008

Division of Minerals

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of March 2008


PLANT OUTPUT

Well No.	Permit No.	KWH Produced	KWH to Sales	Gallons Produced	Average Temp.
27-33	626			0.00 MMgal	Not Flowed
28-33	243			103.37 MMgal	337 Deg F.
37-33	426			44.30 MMgal	341 Deg F.
45-33	627			0.00 MMgal	Not Flowed
63-7	214			62.13 MMgal	331 Deg F.
73-7	77			43.50 MMgal	334 Deg F.
73B-7	428			55.21 MMgal	342 Deg F.
74-7	65			64.60 MMgal	340 Deg F.
76A-7	343			48.50 MMgal	336 Deg F.
82-7	88			0.00 MMgal	Not Flowed
84-7	623			0.00 MMgal	Not Flowed
Totals		35,553.5 MWH	32,274.2 MWH	423.90 MMgal	

This report to be filed by the end of the month following the month herein reported

Water produced for injection augmentation:	Temp.	Production	Pressure
73W-7	80 Deg F.	14.15 MMgal	55 psig.
Goerenger	Not Flowed	0.00 MMgal	Not Flowed

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown

Position Site Manager

Telephone (775) 423-6535

Date 4/21/08

aw

RECEIVED

APR 23 2008

Division of Minerals

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

April 21, 2008


Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the *March* Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

RECEIVED

MAR 07 2008

Division of Minerals

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of February 2008

PLANT OUTPUT

Well No.	Permit No.	KWH Produced	KWH to Sales	Gallons Produced	Average Temp.
27-33	626			0.00 MMgal	Not Flowed
28-33	243			102.49 MMgal	332 Deg F.
37-33	426			0.00 MMgal	Not Flowed
45-33	627			0.00 MMgal	Not Flowed
63-7	214			0.00 MMgal	Not Flowed
73-7	77			0.00 MMgal	Not Flowed
73B-7	428			0.00 MMgal	Not Flowed
74-7	65			0.00 MMgal	Not Flowed
76A-7	343			0.00 MMgal	Not Flowed
82-7	88			0.00 MMgal	Not Flowed
84-7	623			0.00 MMgal	Not Flowed
Totals		1,147.6 MWH	0,000.0 MWH	102.49 MMgal	

This report to be filed by the end of the month following the month herein reported

Water produced for injection augmentation:	Temp.	Production	Pressure
73W-7	80 Deg F.	571.93 MMgal	51 psig.
Goerenger	Not Flowed	0.00 MMgal	Not Flowed

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

*Plant down
 due to
 transmission
 line failure.*

Signature 
 Doug Brown

Position Site Manager

Telephone (775) 423-6535

Date 3/6/08

RECEIVED

MAR 07 2008

Division of Minerals

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

March 6, 2008


Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the February Reports of Production and Injection for the Caithness Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

RECEIVED

FEB 11 2008

Division of Minerals

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of January 2008


PLANT OUTPUT

Well No.	Permit No.	KWH Produced	KWH to Sales	Gallons Produced	Average Temp.
27-33	626			0.00 MMgal	Not Flowed
28-33	243			80.42 MMgal	334 Deg F.
37-33	426			76.01 MMgal	529 Deg F.
45-33	627			0.00 MMgal	Not Flowed
63-7	214			10.30 MMgal	1141 Deg F.
73-7	77			6.18 MMgal	1050 Deg F.
73B-7	428			8.19 MMgal	1172 Deg F.
74-7	65			10.64 MMgal	1314 Deg F.
76A-7	343			6.65 MMgal	1486 Deg F.
82-7	88			0.00 MMgal	Not Flowed
84-7	623			0.00 MMgal	Not Flowed
Totals		6,354.7 MWH	4,781.6 MWH	198.40 MMgal	

This report to be filed by the end of the month following the month herein reported

Water produced for injection augmentation:	Temp.	Production	Pressure
73W-7	71 Deg F.	525.75 MMgal	58 psig.
Goerenger	Not Flowed	0.00 MMgal	Not Flowed

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown
 Position Site Manager

Telephone (775) 423-6535

Date 2/7/08

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

An
RECEIVED

FEB 11 2008

Division of Minerals

February 7, 2008


Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the January Reports of Production and Injection for the Caithness Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator