

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

JAN 15 2010

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of December 2009


PLANT OUTPUT

| Well No. | Permit No. | KWH Produced | KWH to Sales | Gallons Produced | Average Temp. |
|---------------|------------|--------------|--------------|------------------|---------------|
| 27-33 | 626 | | | 376.95 MMgal | 332 Deg F. |
| 28-33 | 243 | | | 117.21 MMgal | 334 Deg F. |
| 37-33 | 426 | | | 0.00 MMgal | Not Flowed |
| 45-33 | 627 | | | 0.00 MMgal | Not Flowed |
| 63-7 | 214 | | | 64.93 MMgal | 318 Deg F. |
| 73-7 | 77 | | | 52.30 MMgal | 320 Deg F. |
| 73B-7 | 428 | | | 68.91 MMgal | 324 Deg F. |
| 74-7 | 65 | | | 66.91 MMgal | 324 Deg F. |
| 76A-7 | 343 | | | 64.68 MMgal | 323 Deg F. |
| 82-7 | 88 | | | 0.00 MMgal | Not Flowed |
| 84-7 | 623 | | | 0.00 MMgal | Not Flowed |
| Totals | | 42,001.3 MWH | 38,266.4 MWH | 811.88 MMgal | |

This report to be filed by the end of the month following the month herein reported

| | | | |
|--------------------------------------------|------------|--------------|------------|
| Water produced for injection augmentation: | Temp. | Production | Pressure |
| 73W-7 | 81 Deg F. | 324.93 MMgal | 87 psig. |
| Goerenger | Not Flowed | 0.00 MMgal | Not Flowed |

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown
 Position Site Manager

Telephone (775) 423-6535

Date January 14, 2010

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

RECEIVED

JAN 15 2010

Division of Minerals

January 14, 2010


Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the *December* Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMS

RECEIVED

DEC 30 2009

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of November 2009


PLANT OUTPUT

| Well No. | Permit No. | KWH Produced | KWH to Sales | Gallons Produced | Average Temp. |
|---------------|------------|--------------|--------------|------------------|---------------|
| 27-33 | 626 | | | 356.76 MMgal | 330 Deg F. |
| 28-33 | 243 | | | 113.06 MMgal | 335 Deg F. |
| 37-33 | 426 | | | 0.00 MMgal | Not Flowed |
| 45-33 | 627 | | | 0.00 MMgal | Not Flowed |
| 63-7 | 214 | | | 63.86 MMgal | 326 Deg F. |
| 73-7 | 77 | | | 52.22 MMgal | 319 Deg F. |
| 73B-7 | 428 | | | 67.60 MMgal | 324 Deg F. |
| 74-7 | 65 | | | 63.45 MMgal | 324 Deg F. |
| 76A-7 | 343 | | | 61.70 MMgal | 322 Deg F. |
| 82-7 | 88 | | | 0.00 MMgal | Not Flowed |
| 84-7 | 623 | | | 0.00 MMgal | Not Flowed |
| Totals | | 38,905.4 MWH | 35,498.4 MWH | 778.64 MMgal | |

This report to be filed by the end of the month following the month herein reported

| | | | |
|--------------------------------------------|------------|--------------|------------|
| Water produced for injection augmentation: | Temp. | Production | Pressure |
| 73W-7 | 82 Deg F. | 544.64 MMgal | 86 psig. |
| Goerenger | Not Flowed | 0.00 MMgal | Not Flowed |

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown
 Position Site Manager

Telephone (775) 423-6535

Date December 29, 2009

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

December 29, 2009

RECEIVED

DEC 30 2009

Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703


Division of Minerals

Dear Ms. Wells:

Enclosed are the November Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

NOV 24 2009

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of October 2009


PLANT OUTPUT

| Well No. | Permit No. | KWH Produced | KWH to Sales | Gallons Produced | Average Temp. |
|---------------|------------|--------------|--------------|------------------|---------------|
| 27-33 | 626 | | | 68.30 MMgal | 323 Deg F. |
| 28-33 | 243 | | | 61.73 MMgal | 334 Deg F. |
| 37-33 | 426 | | | 6.45 MMgal | 337 Deg F. |
| 45-33 | 627 | | | 0.00 MMgal | Not Flowed |
| 63-7 | 214 | | | 36.71 MMgal | 319 Deg F. |
| 73-7 | 77 | | | 30.29 MMgal | 319 Deg F. |
| 73B-7 | 428 | | | 39.28 MMgal | 324 Deg F. |
| 74-7 | 65 | | | 37.90 MMgal | 323 Deg F. |
| 76A-7 | 343 | | | 36.61 MMgal | 321 Deg F. |
| 82-7 | 88 | | | 0.00 MMgal | Not Flowed |
| 84-7 | 623 | | | 0.00 MMgal | Not Flowed |
| Totals | | 21,253.8 MWH | 19,332.6 MWH | 317.28 MMgal | |

This report to be filed by the end of the month following the month herein reported

| | | | |
|--------------------------------------------|------------|--------------|------------|
| Water produced for injection augmentation: | Temp. | Production | Pressure |
| 73W-7 | 84 Deg F. | 557.84 MMgal | 70 psig. |
| Goerenger | Not Flowed | 0.00 MMgal | Not Flowed |

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown

Position Site Manager

Telephone (775) 423-6535

Date November 23, 2009

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

RECEIVED

NOV 24 2009

Division of Minerals

November 23, 2009

Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the October Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

OCT 20 2009

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Division of Minerals

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of September 2009

PLANT OUTPUT

| Well No. | Permit No. | KWH Produced | KWH to Sales | Gallons Produced | Average Temp. |
|---------------|------------|--------------|--------------|------------------|---------------|
| 27-33 | 626 | | | 0.00 MMgal | Not Flowed |
| 28-33 | 243 | | | 99.76 MMgal | 344 Deg F. |
| 37-33 | 426 | | | 93.95 MMgal | 337 Deg F. |
| 45-33 | 627 | | | 0.00 MMgal | Not Flowed |
| 63-7 | 214 | | | 57.10 MMgal | 319 Deg F. |
| 73-7 | 77 | | | 45.88 MMgal | 319 Deg F. |
| 73B-7 | 428 | | | 60.57 MMgal | 324 Deg F. |
| 74-7 | 65 | | | 58.90 MMgal | 324 Deg F. |
| 76A-7 | 343 | | | 61.85 MMgal | 321 Deg F. |
| 82-7 | 88 | | | 0.00 MMgal | Not Flowed |
| 84-7 | 623 | | | 0.00 MMgal | Not Flowed |
| Totals | | 41,418.8 MWH | 37,479.6 MWH | 478.00 MMgal | |

This report to be filed by the end of the month following the month herein reported

| | | | |
|--------------------------------------------|------------|--------------|------------|
| Water produced for injection augmentation: | Temp. | Production | Pressure |
| 73W-7 | 84 Deg F. | 380.19 MMgal | 66 psig. |
| Goerenger | Not Flowed | 0.00 MMgal | Not Flowed |

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown
 Position Site Manager

Telephone (775) 423-6535

Date October 19, 2009

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

RECEIVED

OCT 20 2009

Division of Minerals

October 19, 2009

Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the *September* Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

SEP 17 2009

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of August 2009


PLANT OUTPUT

| Well No. | Permit No. | KWH Produced | KWH to Sales | Gallons Produced | Average Temp. |
|---------------|------------|--------------|--------------|------------------|---------------|
| 27-33 | 626 | | | 0.00 MMgal | Not Flowed |
| 28-33 | 243 | | | 103.41 MMgal | 344 Deg F. |
| 37-33 | 426 | | | 97.38 MMgal | 337 Deg F. |
| 45-33 | 627 | | | 0.00 MMgal | Not Flowed |
| 63-7 | 214 | | | 60.17 MMgal | 320 Deg F. |
| 73-7 | 77 | | | 49.28 MMgal | 319 Deg F. |
| 73B-7 | 428 | | | 64.93 MMgal | 325 Deg F. |
| 74-7 | 65 | | | 62.18 MMgal | 324 Deg F. |
| 76A-7 | 343 | | | 64.38 MMgal | 321 Deg F. |
| 82-7 | 88 | | | 0.00 MMgal | Not Flowed |
| 84-7 | 623 | | | 0.00 MMgal | Not Flowed |
| Totals | | 42,924.5 MWH | 38,822.7 MWH | 501.73 MMgal | |

This report to be filed by the end of the month following the month herein reported

| | | | |
|--------------------------------------------|------------|--------------|------------|
| Water produced for injection augmentation: | Temp. | Production | Pressure |
| 73W-7 | 84 Deg F. | 233.13 MMgal | 32 psig. |
| Goerenger | Not Flowed | 0.00 MMgal | Not Flowed |

I hereby certify that the above information given herewith is true, correct, and complete, to the best of my knowledge.

Signature 
 Doug Brown

Position Site Manager

Telephone (775) 423-6535

Date September 16, 2009

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

RECEIVED

SEP 17 2009

September 16, 2009

Division of Minerals


Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the August Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

AUG 13 2009

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of July 2009


PLANT OUTPUT

| Well No. | Permit No. | KWH Produced | KWH to Sales | Gallons Produced | Average Temp. |
|---------------|------------|--------------|--------------|------------------|---------------|
| 27-33 | 626 | | | 0.00 MMgal | Not Flowed |
| 28-33 | 243 | | | 104.40 MMgal | 343 Deg F. |
| 37-33 | 426 | | | 98.32 MMgal | 336 Deg F. |
| 45-33 | 627 | | | 0.00 MMgal | Not Flowed |
| 63-7 | 214 | | | 61.19 MMgal | 321 Deg F. |
| 73-7 | 77 | | | 48.38 MMgal | 320 Deg F. |
| 73B-7 | 428 | | | 63.87 MMgal | 324 Deg F. |
| 74-7 | 65 | | | 63.18 MMgal | 324 Deg F. |
| 76A-7 | 343 | | | 64.35 MMgal | 321 Deg F. |
| 82-7 | 88 | | | 0.00 MMgal | Not Flowed |
| 84-7 | 623 | | | 0.00 MMgal | Not Flowed |
| Totals | | 43,281.0 MWH | 39,089.0 MWH | 503.70 MMgal | |

This report to be filed by the end of the month following the month herein reported

| | | | |
|--------------------------------------------|------------|--------------|------------|
| Water produced for injection augmentation: | Temp. | Production | Pressure |
| 73W-7 | 83 Deg F. | 486.14 MMgal | 46 psig. |
| Goerenger | Not Flowed | 0.00 MMgal | Not Flowed |

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown

Position Site Manager

Telephone (775) 423-6535

Date August 12, 2009

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

RECEIVED

AUG 13 2009

Division of Minerals

August 12, 2009


Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the July Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

JUL 17 2009

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of June 2009


PLANT OUTPUT

| Well No. | Permit No. | KWH Produced | KWH to Sales | Gallons Produced | Average Temp. |
|---------------|------------|--------------|--------------|------------------|---------------|
| 27-33 | 626 | | | 0.00 MMgal | Not Flowed |
| 28-33 | 243 | | | 100.56 MMgal | 343 Deg F. |
| 37-33 | 426 | | | 94.70 MMgal | 336 Deg F. |
| 45-33 | 627 | | | 0.00 MMgal | Not Flowed |
| 63-7 | 214 | | | 59.26 MMgal | 321 Deg F. |
| 73-7 | 77 | | | 47.45 MMgal | 320 Deg F. |
| 73B-7 | 428 | | | 62.64 MMgal | 325 Deg F. |
| 74-7 | 65 | | | 61.18 MMgal | 324 Deg F. |
| 76A-7 | 343 | | | 61.58 MMgal | 322 Deg F. |
| 82-7 | 88 | | | 0.00 MMgal | Not Flowed |
| 84-7 | 623 | | | 0.00 MMgal | Not Flowed |
| Totals | | 41,982.9 MWH | 37,930.3 MWH | 487.38 MMgal | |

This report to be filed by the end of the month following the month herein reported

| | | | |
|--------------------------------------------|------------|--------------|------------|
| Water produced for injection augmentation: | Temp. | Production | Pressure |
| 73W-7 | 81 Deg F. | 524.36 MMgal | 67 psig. |
| Goerenger | Not Flowed | 0.00 MMgal | Not Flowed |

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown

Position Site Manager

Telephone (775) 423-6535

Date July 16, 2009

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

RECEIVED

JUL 17 2009

Division of Minerals

July 16, 2009

Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the *June* Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 850-2266 should you have any questions.

Sincerely,

Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

JUN 05 2009

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of May 2009

PLANT OUTPUT

| Well No. | Permit No. | KWH Produced | KWH to Sales | Gallons Produced | Average Temp. |
|---------------|------------|--------------|--------------|------------------|---------------|
| 27-33 | 626 | | | 0.00 MMgal | Not Flowed |
| 28-33 | 243 | | | 103.21 MMgal | 343 Deg F. |
| 37-33 | 426 | | | 97.20 MMgal | 336 Deg F. |
| 45-33 | 627 | | | 0.00 MMgal | Not Flowed |
| 63-7 | 214 | | | 61.84 MMgal | 320 Deg F. |
| 73-7 | 77 | | | 49.21 MMgal | 320 Deg F. |
| 73B-7 | 428 | | | 64.97 MMgal | 324 Deg F. |
| 74-7 | 65 | | | 63.85 MMgal | 324 Deg F. |
| 76A-7 | 343 | | | 64.00 MMgal | 321 Deg F. |
| 82-7 | 88 | | | 0.00 MMgal | Not Flowed |
| 84-7 | 623 | | | 0.00 MMgal | Not Flowed |
| Totals | | 40,241.9 MWH | 36,210.7 MWH | 504.27 MMgal | |

This report to be filed by the end of the month following the month herein reported

| | | | |
|--------------------------------------------|------------|--------------|------------|
| Water produced for injection augmentation: | Temp. | Production | Pressure |
| 73W-7 | 83 Deg F. | 550.56 MMgal | 82 psig. |
| Goerenger | Not Flowed | 0.00 MMgal | Not Flowed |

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown

Position Site Manager

Telephone (775) 423-6535

Date June 4, 2009

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

RECEIVED

JUN 05 2009

Division of Minerals

June 4, 2009

Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the May Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

MAY 08 2009

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of April 2009


PLANT OUTPUT

| Well No. | Permit No. | KWH Produced | KWH to Sales | Gallons Produced | Average Temp. |
|---------------|------------|--------------|--------------|------------------|---------------|
| 27-33 | 626 | | | 0.00 MMgal | Not Flowed |
| 28-33 | 243 | | | 99.68 MMgal | 343 Deg F. |
| 37-33 | 426 | | | 93.87 MMgal | 335 Deg F. |
| 45-33 | 627 | | | 0.00 MMgal | Not Flowed |
| 63-7 | 214 | | | 59.70 MMgal | 320 Deg F. |
| 73-7 | 77 | | | 48.14 MMgal | 320 Deg F. |
| 73B-7 | 428 | | | 63.56 MMgal | 324 Deg F. |
| 74-7 | 65 | | | 61.64 MMgal | 324 Deg F. |
| 76A-7 | 343 | | | 61.52 MMgal | 322 Deg F. |
| 82-7 | 88 | | | 0.00 MMgal | Not Flowed |
| 84-7 | 623 | | | 0.00 MMgal | Not Flowed |
| Totals | | 38,332.5 MWH | 34,637.8 MWH | 488.11 MMgal | |

This report to be filed by the end of the month following the month herein reported

| | | | |
|--------------------------------------------|------------|--------------|------------|
| Water produced for injection augmentation: | Temp. | Production | Pressure |
| 73W-7 | 82 Deg F. | 509.28 MMgal | 82 psig. |
| Goerenger | Not Flowed | 0.00 MMgal | Not Flowed |

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown

Position Site Manager

Telephone (775) 423-6535

Date May 7, 2009

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

RECEIVED

MAY 08 2009

Division of Minerals

May 7, 2009

Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the April Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

APR 09 2009

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of March 2009


PLANT OUTPUT

| Well No. | Permit No. | KWH Produced | KWH to Sales | Gallons Produced | Average Temp. |
|---------------|------------|--------------|--------------|------------------|---------------|
| 27-33 | 626 | | | 0.00 MMgal | Not Flowed |
| 28-33 | 243 | | | 103.28 MMgal | 342 Deg F. |
| 37-33 | 426 | | | 97.26 MMgal | 334 Deg F. |
| 45-33 | 627 | | | 0.00 MMgal | Not Flowed |
| 63-7 | 214 | | | 59.07 MMgal | 319 Deg F. |
| 73-7 | 77 | | | 47.76 MMgal | 320 Deg F. |
| 73B-7 | 428 | | | 63.17 MMgal | 324 Deg F. |
| 74-7 | 65 | | | 60.99 MMgal | 324 Deg F. |
| 76A-7 | 343 | | | 61.72 MMgal | 322 Deg F. |
| 82-7 | 88 | | | 0.00 MMgal | Not Flowed |
| 84-7 | 623 | | | 0.00 MMgal | Not Flowed |
| Totals | | 42,342.0 MWH | 38,453.7 MWH | 493.25 MMgal | |

This report to be filed by the end of the month following the month herein reported

| | | | |
|--------------------------------------------|------------|--------------|------------|
| Water produced for injection augmentation: | Temp. | Production | Pressure |
| 73W-7 | 82 Deg F. | 496.24 MMgal | 82 psig. |
| Goerenger | Not Flowed | 0.00 MMgal | Not Flowed |

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown

Position Site Manager

Telephone (775) 423-6535

Date April 8, 2009

Terra-Gen Dixie Valley, LLC

P.O. Box 1270

Fallon, Nevada 89407

(775) 423-6535 • Fax: (775) 423-8048

April 8, 2009

RECEIVED

APR 09 2009

Division of Minerals

Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the *March* Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

MAR 06 2009

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of February 2009

PLANT OUTPUT

| Well No. | Permit No. | KWH Produced | KWH to Sales | Gallons Produced | Average Temp. |
|---------------|------------|---------------------|---------------------|---------------------|---------------|
| 27-33 | 626 | | | 0.00 MMgal | Not Flowed |
| 28-33 | 243 | | | 95.45 MMgal | 337 Deg F. |
| 37-33 | 426 | | | 89.89 MMgal | 331 Deg F. |
| 45-33 | 627 | | | 0.00 MMgal | Not Flowed |
| 63-7 | 214 | | | 2.76 MMgal | 318 Deg F. |
| 73-7 | 77 | | | 46.82 MMgal | 319 Deg F. |
| 73B-7 | 428 | | | 61.78 MMgal | 323 Deg F. |
| 74-7 | 65 | | | 71.16 MMgal | 322 Deg F. |
| 76A-7 | 343 | | | 57.37 MMgal | 321 Deg F. |
| 82-7 | 88 | | | 0.00 MMgal | Not Flowed |
| 84-7 | 623 | | | 0.00 MMgal | Not Flowed |
| Totals | | 37,191.3 MWH | 33,711.2 MWH | 425.22 MMgal | |

This report to be filed by the end of the month following the month herein reported

| | | | |
|--------------------------------------------|------------|--------------|------------|
| Water produced for injection augmentation: | Temp. | Production | Pressure |
| 73W-7 | 82 Deg F. | 452.80 MMgal | 82 psig. |
| Goerenger | Not Flowed | 0.00 MMgal | Not Flowed |

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown

Position Site Manager

Telephone (775) 423-6535

Date 3/5/09

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

March 5, 2009

RECEIVED

MAR 06 2009

Division of Minerals


Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the February Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator

STATE OF NEVADA
 COMMISSION ON MINERAL RESOURCES
DIVISION OF MINERALS
 400 W. King Street, Suite 106
 Carson City, Nevada 89703
 (775) 684-7040

ORIGINAL-Div. File
 DUPLICATE-Div. NBMG

RECEIVED

FEB 13 2009

Division of Minerals

**COMMERCIAL AND INDUSTRIAL CLASS
 GEOTHERMAL ELECTRIC PRODUCERS MONTHLY REPORT**

Company Terra-Gen Dixie Valley, LLC Address 9590 Prototype Court, Suite 200, Reno, Nevada 89521

Project Dixie Valley Unit County Churchill Month of January 2009

PLANT OUTPUT

| Well No. | Permit No. | KWH Produced | KWH to Sales | Gallons Produced | Average Temp. |
|---------------|------------|--------------|--------------|------------------|---------------|
| 27-33 | 626 | | | 0.00 MMgal | Not Flowed |
| 28-33 | 243 | | | 104.30 MMgal | 337 Deg F. |
| 37-33 | 426 | | | 98.30 MMgal | 330 Deg F. |
| 45-33 | 627 | | | 0.00 MMgal | Not Flowed |
| 63-7 | 214 | | | 0.00 MMgal | 0 Deg F. |
| 73-7 | 77 | | | 50.56 MMgal | 318 Deg F. |
| 73B-7 | 428 | | | 66.70 MMgal | 322 Deg F. |
| 74-7 | 65 | | | 72.61 MMgal | 321 Deg F. |
| 76A-7 | 343 | | | 63.10 MMgal | 321 Deg F. |
| 82-7 | 88 | | | 0.00 MMgal | Not Flowed |
| 84-7 | 623 | | | 0.00 MMgal | Not Flowed |
| Totals | | 40,622.4 MWH | 36,910.0 MWH | 455.57 MMgal | |

This report to be filed by the end of the month following the month herein reported

| | | | |
|--------------------------------------------|------------|--------------|------------|
| Water produced for injection augmentation: | Temp. | Production | Pressure |
| 73W-7 | 81 Deg F. | 499.35 MMgal | 82 psig. |
| Goerenger | Not Flowed | 0.00 MMgal | Not Flowed |

I hereby certify that the above information given herewith is true, correct, and complete to the best of my knowledge.

Signature 
 Doug Brown
 Position Site Manager

Telephone (775) 423-6535

Date 2/12/09

Terra-Gen Dixie Valley, LLC

P.O. Box 1270
Fallon, Nevada 89407
(775) 423-6535 • Fax: (775) 423-8048

RECEIVED

FEB 13 2009

Division of Minerals

February 12, 2009

Ms. Linda Wells
Division of Minerals
400 West King Street, Suite 106
Carson City, NV 89703

Dear Ms. Wells:

Enclosed are the January Reports of Production and Injection for the Terra-Gen Dixie Valley Power Project plus a copy for the Nevada Bureau of Mines and Geology.

Well 27-32 remained shut in during the month. Permitted use of Well 27-32 is being changed from an injection well to a dedicated monitor well.

Please call my office or Missy Miller at 775-850-2266 should you have any questions.

Sincerely,



Doug Brown, Site Manager

Cc: Missy Miller, Sr. Compliance Coordinator